

B



07 - - 19 19

Le progrès, une passion à partager
LABORATOIRE DE TRAPPES
29 avenue Roger Hennequin - 78197 Trappes Cedex
Tél : 01 30 69 10 00 - Fax : 01 30 69 12 34

File G031707 - Document CEMATE/45 - Page 1/4

EUROPEAN REACTION TO FIRE CLASSIFICATION REPORT ACCORDING TO THE EUROPEAN STANDARD EN 13501-1

Notified Body by the French State besides the European Commission under number : 0071

Product standard : NF EN 14041
Resilient, textile and laminate floorcoverings

(free translation of French classification report n°G031707 CEMATE/44)

N°G031707 - CEMATE/45

Material submitted by :	GERFLOR 50 Cours de la République 69627 VILLEURBANNE Cedex FRANCE
Commercial trademark :	TARASAFE PLUS
Production site :	GERFLOR Tarare 43 Boulevard Garibaldi 69170 TARARE
Brief description :	Floorcovering in PVC
Date of report :	2006, July 13 th

**Only full reproduction of the present document is authorized.
It contains 4 pages**

Laboratoire national de métrologie et d'essais

Établissement public à caractère industriel et commercial • Siège social : 1, rue Gaston Boissier - 75724 Paris Cedex 15 • Tél. : 01 40 43 37 00
Fax : 01 40 43 37 37 • E-mail : info@lne.fr • Internet : www.lne.fr • Siret : 313 320 244 00012 • NAF : 743 B • TVA : FR 92 313 320 244
Barclays Paris Centrale IBAN : FR76 3058 8600 0149 7267 4010 170 BIC : BARCFRPP

1. INTRODUCTION

This classification report defines the classification assigned to product in accordance with the procedures given in EN 13501-1.

2. DETAILS OF CLASSIFIED PRODUCT

2.1. NATURE AND END USE APPLICATION

VFHE type (NF EN 649 standard) floorcovering.

2.2. DESCRIPTION

Characteristics product :

Product	Thickness in mm	Mass per unit square meter in g/m ²
TARASAFE PLUS	<p>Wearing layer :</p> <p>Calendered plasticized PVC with incrustation of particles of carbide of silicium and coloured grains of PVC 1,20 mm</p> <p>Backing :</p> <p>Calendered plasticized PVC reinforced of a complex non-woven material / glass fibre grid + textile backing 1,30 mm</p> <p>Total thickness : 2,50 mm Tolerance : -0.15/+18</p>	<p>3150 Tolerance : -10/+13 %</p>

Text report to be followed on next page

3. TEST REPORTS AND TEST RESULTS IN SUPPORT OF THIS CLASSIFICATION

3.1. TEST REPORTS

Name of laboratory	Name of sponsor	Test report ref. n°	Test method
Laboratoire national de métrologie et d'essais 29 av. Roger Hennequin 78197 TRAPPES CEDEX	GERFLOR 50 Cours de la République 69627 VILLEURBANNE Cedex	File : G031707 CEMATE/43	Radiant panel EN ISO 9239-1

3.2. TEST RESULTS FOR FLOORINGS

Test method	Number of tests	Parameters	Results
EN ISO 9239-1 Glued to a fibre cement board	4	Critical flux (kW/m ²) Smoke (%.min)	8.23 232

Text report to be followed on next page

4. CLASSIFICATION AND DIRECT FIELD APPLICATION

4.1. CLASSIFICATION

Fire behaviour	Smoke production	Flaming droplets
B_{fl}	s1	-

4.2. FIELD OF APPLICATION

This classification is valid for the product mentioned in § 2.2 or strictly and equally stipulated in the quoted production site.

Colour : various

Thickness : about 2,5 mm

Glued to A1 and A2 classified substrates

5. LIMITATIONS

5.1. RESTRICTIONS CONCERNING THE VALIDITY PERIOD OF THE CLASSIFICATION REPORT

None.

5.2. WARNING

This document does not represent type approval or certification of the product.

Trappes, the 13th of July 2006

The Head of Fire Behaviour Division



Alain SAINRAT



Test Officer



Luc CHEVALIER